



**Code Compliance Evaluation**  
**Royalite Residential Series Acrylic Dome**  
**and**  
**Single-lite Glass Skylights**

**The Royalite Residential Series Acrylic Dome and Single-lite Glass Skylights meet the Structural loading requirements of the 2016 California Building Code (CBC) and the 2015 International Building Code.**

I have investigated the status of the Royalite Residential Series Skylights as compared with the requirements of the American Architectural Manufacturer's Association specification (AAMA/WDMA/CSA 101/I.S.2/A440-08) which is cited in the 2016 CBC.

The specific requirements for the materials, installation and allowable loads called for are acceptable under the current codes. Royalite products meet or exceed the AAMA/WDMA/CSA 101/I.S.2/A440 design requirements for the positive and negative design loads. The fixed units exceed the loading requirements of the Performance Class CW (40psf) and the operable units exceed the requirements of the Performance Class R (25psf).

Michael "Tony" Regan  
Structural Engineer  
10580 N. McCarran Blvd. #115-181  
Reno, NV. 89503  
(775) 741-2568  
tgregan@aol.com

